

J & S Valve™

Specifications

Metal Seated Solid Wedge Gate Valve

Non Rising Stem Type (NRS) and Outside Screw & Yoke (OS&Y)

Metal Seated Gate Valve shall be NRS or OS&Y and meet or exceed AWWA C500-93 Specifications. The valve body, bonnet, wedge, gland, and handwheel or nut, shall be constructed of ductile iron. Stem material to be stainless steel. All valves shall have non asbestos graphite packing. Valve body shall be coated inside and outside as specified. Nuts, bolts, and washers to be stainless steel. End Connections to be flange or mechanical joint. Valves 18" & larger shall be equipped with a bevel or spur gear operator. Valves shall be J & S Valve™ Series 3800 or 3700 or engineer's pre-approved equal.

Contact us for these specification in Microsoft Word Format.

J & S Valve™

Registered Trade Mark of J & S Valve, Inc.

2323 1st Street ▪ Huffman, Texas 77336

Phone: 281-324-3990 ▪ Fax: 281-324-4595

Email: sales@JandSValve.com ▪ Web Site: www.JandSValve.com