

## HOW TO SELECT PROPER VALVE SIZE FOR VERTICAL TURBINE PUMP INSTALLATIONS

1. Determine the pump gpm at the no head condition. The no head flow rate usually ranges between 125-150% of the rated flow at operating conditions.
2. Select valve model number from table below corresponding to the given flow rate.
3. Model numbers with the "T" suffix include a dual port throttling device and have a higher capacity. 4" and larger valves include an anti-slam device with stainless steel trim.
4. When a power operated check valve is used, a well service air release valve is recommended and sized to limit the velocity of the water rise to 2 ft/sec.

VALVE SIZE	NO HEAD PUMP CAPACITY, GPM	MODEL NUMBER	
		150 PSI MODEL	300 PSI MODEL
1/2" NPT	0-200	100WS	
	0-350	100T	
1" NPT	201-500	101WS	
	351-1,350	101T	
2" NPT	501-1,200	102WS	
	1,351-4,000	102T	
3" NPT	1,201-2,000	103WS	
	4,001-7,000	103T	
4" FLG'D	7,001-11,000	104WS.2	154WS.2
6" FLG'D	11,001-24,000	106WS.2	156WS.2
8" FLG'D	24,001-50,000	108WS.2	158WS.2
10" FLG'D	50,001-70,000	110WS.2	160WS.2
12" FLG'D	70,001-110,000	112WS.2	162WS.2

Contact us for more information: Valve & Equipment Consultants, Inc. • Phone: 281-324-1500 • Email: [sales@valveandequipment.com](mailto:sales@valveandequipment.com)

Website: [www.ValveAndEquipment.com](http://www.ValveAndEquipment.com)

Revised 7-10-98

**WELL SERVICE AIR VALVE SIZING**

DATE 8-5-96

**VAL-MATIC®** VALVE AND MANUFACTURING CORP.

DRWG. NO.

**SS-1018**